



Certificate of Test

ASTM C150 Type I/II
AASHTO M85 Type I/II

April 10, 2017
Lot 60-90

C150 Chemical Requirements – Table 1

Item	Spec Limit	Result
Al ₂ O ₃	N/A	4.0
Fe ₂ O ₃	N/A	3.4
MgO	6.0 Max	1.0
SO ₃	2.3*	3.3
L.O.I.	3.5 Max	2.8
Insoluble Residue	1.5 Max	0.99

*Does not apply. In compliance with Footnote D, Table 1, ASTM Standard Specification C150 and AASHTO Standard Specification M85.

C150 Physical Requirements – Table 3

Item	Spec Limit	Result
Blaine Specific Surface, m ² /kg	260 Min	391
Air Content of Mortar, Vol %	12 Max	7.8
Autoclave Expansion, %	0.80 Max	0.01
Vicat Initial Time of Set, minutes	45 Min	90
Vicat Final Time of Set, minutes	375 Max	190
Compressive Strength, psi:	3 Days	1740 Min 3800
	7 Days	2760 Min 4770
	Lot 32-59 28 Days	3050 Min 5990

Compound Composition

Item	Spec Limit	Result
C ₃ A, %	8 Max	5
Inorganic Processing Addt's, %	5.0 Max	0
CaCO ₃ in Limestone, %	70 Min	93.0
Limestone Additions	5.0 Max	4.8
C1038 Mortar Bar Expansion, %	0.020% Max	0.014

This cement has been sampled and tested in accordance with ASTM standard methods and procedures. Cement analysis are reported as oxides, in accordance with ASTM Test Method C114. This cement is manufactured at our Laramie, Wyoming facility. All test results are certified to comply with the type and specification designated. We are not responsible for improper use or workmanship.

Bob Kersey, Chief Chemist



AASHTO Accredited Since 1996